



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 6/29/09

Code 48.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title R403.1.2 Continuous footing in Seismic Design Categories D ₀ , D ₁ and D ₂		Page 1 of 1
Proponent Craig Wagner	Title Chief Building Inspector/ IABO Code Comm. Member	
Address 220 W Van Buren St, Columbia City IN 46725		Phone 260-248-3111
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>R403.1.2 Continuous fFootings in Seismic Design Categories D₀, D₁ and D₂. The <i>braced wall panels</i> at exterior walls of buildings located in Seismic Design Categories D₀, D₁ and D₂ shall be supported on continuous footings. All required interior <i>braced wall panels</i> in buildings with plan dimensions greater than 50 feet (15 240mm) shall also be supported by continuous footings.</p>		
REASON AND FISCAL IMPACT		
<p>This proposal removes the word “continuous” from the section as it is often misinterpreted to mean that the footing must all be poured, or placed, at onetime.</p> <p>Fiscal impact: no cost to construction.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		